




FRONT ELEVATION LESS FRONTS



ONE LINE DIAGRAM



FRONT ELEVATION ENCLOSED




SECTION A-A

SYSTEM	CATALOG #	INTERIOR DWG. #	WITHSTAND RATING	SHIPPING WEIGHT
3Ø 3W *	CT163-FECD	03350.02	100,000A	300
3Ø 4W	CT164-FECD	03350.03	100,000A	320

* CHECK WITH UTILITY CO. FOR SUITABILITY OF THIS EQUIPMENT

NOTES:
 THIS EQUIPMENT IS FURNISHED IN TYPE 3R ALUMINUM ENCLOSURES.
 THE METERING TRANSFORMER CABINET IS LISTED BY UNDERWRITERS LABORATORIES INC. AND HAS AN UNPROTECTED SHORT CIRCUIT CURRENT RATING OF 100,000 R.M.S. SYM. AMPERES.



1600A 600V CURRENT TRANSFORMER CABINETS FIRST ENERGY CORP.	CT-03350.23
ERICKSON ELECTRICAL EQUIP. CO. 475 BONNIE LANE ELK GROVE VILLAGE, IL 60007	6/7/93 BE 3/23/06 KE 6/21/07 KE 7/23/07 KE